



CAMPBELLVILLE FIRE-RESCUE

Chris Taylor, Fire Chief

100 West Broadway
Campbellsville, KY 42718
Phone: 270-465-4131

Email: chris.taylor@campbellsville.us

Fireworks Code Regulations for Tent and Temporary Stands

NO SMOKING SIGNS

Pass or Fail	Description	NFPA Reference
	NO Smoking in or within 50 feet of Consumer Fireworks Retail Sales (CFRS)	NFPA 1 – 65.10.3.11.1
	NO smoking signs posted at each entrance or within 10 feet of every aisle. "FIREWORKS – NO SMOKING" signs posted in 2 inch lettering with contrast background	NFPA 1 – 65.10.3.11.2

**NOTE: In accordance with NFPA 1 Section 65.10.4.8.3 and 65.10.4.8.4, exit signs and emergency lights are not required for tents to be illuminated that are not open for business after dusk in accordance with NFPA 1124 section 7.4.8.3 and 7.4.8.4.

SEPARATION DISTANCES FOR TEMPORARY CONSUMER FIREWORKS RETAIL SALES

Pass or Fail	Description	NFPA Reference
	50 feet from motor fuel dispensing station	NFPA 1 – 65.10.3.12.2
	50 feet from retail propane dispensing station	NFPA1 - 65.10.3.12.1
	50 feet from aboveground storage tank (AGST)	NFPA1 - 65.10.3.12.1
	300 feet from bulk fuel dispensing or bulk storage	NFPA 1 – 65.10.3.12.6
	20 feet from buildings	NFPA 1 – 65.10.4.7.2
	20 feet from combustibles	NFPA 1 – 65.10.4.7.2
	10 feet from parked vehicles	NFPA 1 – 65.10.4.7.2
	20 feet from storage of consumer fireworks	NFPA 1 – 65.10.4.7.2
	20 feet from generator fuel storage	NFPA 1 – 65.10.4.9.2.3
	20 feet from generator placement	NFPA 1 – 65.10.4.9.2.2
	20 feet from cooking equipment	NFPA 1 – 65.10.4.9.3.1
	50 feet from any open flame cooking equipment	NFPA 1 – 65.10.4.9.3.2

PROPER USE OF EXTENSION CORDS

Pass or Fail	Description	NFPA Reference
	Extension cords maintained in good working condition	NFPA 1 – 11.1.7
	Extension cords shall be grounded when serving ground appliances.	NFPA 1 – 11.1.7
	Extension cords cannot be used as permanent wiring.	NFPA 1 – 11.1.7
	Extension cords shall be rated for its use.	NFPA 1 – 11.1.7
	Extension cords shall be plugged directly into an approved receptacle, powertap or multi-plug adapter.	NFPA 1 – 11.1.7

FIRE EXTINGUISHERS

Pass or Fail	Description	NFPA Reference
	Travel distance to extinguisher shall be 35 feet or less	NFPA 1 – 65.10.4.5.2
	Every CFRS facility and store shall have a minimum of 2 portable Fire extinguishers (one 2A rating and one 2 ½ gallon pressurized water type extinguisher)	NFPA 1 -65.10.3.6.3

NOTIFICATIONS TO LOCAL FIRE DEPARTMENT OF STORAGE

Pass or Fail	Description	NFPA Reference
	(Shall include address of sales, address, where fireworks are stored, and how they are stored, copy of shipping bill or manifest and whether fireworks are consumer, theatrical pyro or display.)	KRS 227.752(3)

	24 hours to comply with any non-imminent danger violations.	KRS 227.752(4)
--	---	----------------

DISCHARGING FIREWORKS SIGNAGE

Pass or Fail	Description	NFPA Reference
	One sign shall be posted on exterior of each side of the CFRS stating "No fireworks discharge within 200 feet." 4 Inch lettering on contrast Background.	NFPA 1 – 65.10.4.6.3 KRS 227.715(11)

IGNITION OF FIREWORKS

Pass or Fail	Description	NFPA Reference
	Person lawfully possessing consumer fireworks may use them if: 18 years old, fireworks not ignited within 200 feet of any structure, vehicle or other person.	KRS 227.715(11)

TEMPORARY STANDS (NOT ACCESSIBLE TO THE PUBLIC)

Pass or Fail	Description	NFPA Reference
	Maximum height of displays – 8 feet.	NFPA 1 – 65.10.6.4.3
	Items shall not be required to have covered fuses	NFPA 1 – 65.10.6.4.5
	Fireworks shall be displayed in a manner that prevents handling by persons other than staff	NFPA 1 – 65.10.6.4.6

TEMPORARY STANDS (ACCESSIBLE TO THE PUBLIC)

Pass or Fail	Description	NFPA Reference
	Stands less than 200 square feet only 1 fire extinguisher required	NFPA 1 – 65.10.6.2.1
	Approved safety and evacuation plan not required	NFPA 1 – 65.10.6.2.2
	Travel distance to exits shall not exceed 35 feet	NFPA 1 - 65.10.6.2.3.2

UNDER THE INFLUENCE

Pass or Fail	Description	NFPA Reference
	NO sale of fireworks to anyone obviously under the influence of alcohol or drugs	NFPA 1 – 65.10.3.23

TRAINING

Pass or Fail	Description	NFPA Reference
	All personnel handling consumer fireworks shall receive training to the performance of their duties.	NFPA 1 – 65.10.3.22

BUILDING PERMIT FOR TENT

Pass or Fail	Description	NFPA Reference
	Building permit must be obtained to the installation or erection of a tent over 399 square feet	2013 KBC – 105.1

- Fireworks registration displayed conspicuously for each location selling fireworks KRS 227.715(6)
- No person under 18 years old shall sell consumer fireworks at CFRS facility KRS 227.715(9) without supervision of parent or guardian
- No person shall give, offer for sell any consumer fireworks to anyone under KRS 227.715(8) 18 years old

Vendor Signature and Date	Fire Inspector Signature and Date
----------------------------------	--